

Return address: P.O. Box 2220, 6802 CE ARNHEM, The Netherlands

Van Merksteijn Plastics B.V.
Att. Mr. H. Hermelink
Verzetslaan 20
7548 EN ENSCHEDE
The Netherlands

TÜV Rheinland Nederland B.V.
The Netherlands

Postal address:
P.O. Box 2220
6802 CE ARNHEM

Parking and delivery:
Westervoortsedijk 73
6827 AV ARNHEM

www.tuv.com/nl

T +31 88 888 7888

Jaring.de.Wolff@nl.tuv.com

Report

Project number: 89209409
Report number: 89209409.03en

Date
16/03/2016

Project number
89209409

Report number
89209409.03en

Received:

A floor covering foil, marked as: **“Floorgraphics film with special structure printed solvent ink”**;

TÜV-reference: MT16-95437.03

Phone number client
+31 (0) 53 4289900

Sampling procedure:

The samples are selected by the applicant. The test house has had no influence on the sampling procedure.

Fax number client
+31 (0) 53 4289200

The samples have been received on 23/02/2016.

Order:

To determine the slip resistance according DIN 51130:2014*.

** The test is completely or partially conducted by a subcontractor*

Article
Floorgraphics film with special structure printed with solvent ink

Appendix
- none -

Results:

See page three.

Appendix:

None.

TRN applies General Terms & Conditions which are filed at the office of the Clerk for civil affairs at the Court in Zutphen (the Netherlands) under number 35/2010, dated November 17th 2010.

PRODUCT IDENTIFICATION

Applicant : Van Merksteijn Plastics B.V.
Name : **Floorgraphics film with special structure
printed with solvent ink***

** Applicant's declaration*

Date
16/03/2016

Project number
89209409

Report number
89209409.03en

Article
Floorgraphics film with special
structure printed with solvent ink

Page
2/3



Figure 1, Picture of the received sample

TEST RESULTS

Slip resistance - Ramp test
Method DIN 51130:2014

Date of testing : 14/03/2016

Mean angle of acceptance, α_{ges} : 11.3°

Slip resistance classification : R10

Date
16/03/2016


Project number
89209409

Report number
89209409.03en


Article
Floorgraphics film with special
structure printed with solvent ink

Page
3/3

Author:
Mr. J. de Wolff



Review:
Mrs. E. Zwier



All rights reserved.

No part of this report may be reproduced, provided to and/or examined by third parties, and/or published by print, photoprint, microfilm, in electronic form or any other means without the explicit previous written consent of TÜV Rheinland Nederland B.V. The results are based upon the samples received and have not to be representative for the total production. TÜV Rheinland Nederland B.V. had no influence on the sampling.

In case this report was drafted within the context of an assignment to TÜV Rheinland Nederland B.V., the rights and obligations of contracting parties are subject to the General Terms & Conditions for Advisory, Research and Certification assignments to TÜV Rheinland Nederland B.V. and/or the relevant agreement concluded between the contracting parties.

© 2010 TÜV Rheinland Nederland B.V.

(end of report)